

# SAFETY VALVE TEST REPORT

## GENERAL

Company : ATEI  
Plant : CENRAL  
Location : GIJON  
Valve Identification : 21423UIGFAU  
Mfg Serial Number : 12345457  
  
Work Order : 8723584238  
Technician : JUAN

## VALVE INFORMATION

Manufacturer : CROSBY  
Model : 1700  
Size : N/A  
Orifice : 6  
Name Plate Set Pressure : 6.25 kgs/cm<sup>2</sup>

## TOLERANCE

Code Section : ASME Sec I 301-1000 psi (21.21-70.45 kg/cm<sup>2</sup>)  
AS FOUND Tolerance : ±0.70 kgf/cm<sup>2</sup> 4.20 – 4.30 kgf/cm<sup>2</sup>  
AS LEFT Tolerance : ±0.70 kgf/cm<sup>2</sup> 4.20 – 4.30 kgf/cm<sup>2</sup>

## COMMENTS

## SENSORS

Load : Interface 10K 1bf (4536 kgf) SN 337367  
Acoustic : PCB 130D20

## TEST COMMENTS

## TEST RESULTS

File	(kgf/cm <sup>2</sup> ) Set	(kgf/cm <sup>2</sup> ) Line	Tolerance	Deviation
1 AS FOUND Nov 08 2012 10_25_57.atd	0.00	0.00	0.7 kgf/cm <sup>2</sup>	No Detection

Testing performed using the VisualTEST System Version 8.0.9.16 in accordance with tolerance criteria specified above.

Valve \_\_\_\_\_ was Found OUTSIDE tolerance.

Approved: \_\_\_\_\_

Date: \_\_\_\_\_

Accepted: \_\_\_\_\_

Date: \_\_\_\_\_

